

Depth of Water Penetration Under Pressure

Report No:	UXB0598988/389/M 1	Report Date:	21 June 2024
		Our Contract Ref:	51078456
Client:	TCO International Holdings LTD	Date Cast: Date	1 May 2024
Address:	128 City Road London, EC1V 2NX GB	Sampled: Date	1 May 2024
Client Contact:	Not Advised	Received: Date	18 Jun 2024
		Tested:	18 Jun 2024 -
Site:	128 City Road, London, EC1V 2NX	Tested By:	SOCOTEC Uxbridge
Location:	Not given	Sampling Certificate:	Not Received
Mix Details:	EcoZmart	Sampled by:	Client
Sample Type:	Cube		

Results:

Laboratory Reference:	27377387	27377388	27377389
Client Ref:	A	B	C
Width / Diameter (mm):	152	152	152
Condition Upon Receipt:	Satisfactory	Satisfactory	Satisfactory
Direction of water pressure relative to casting direction:	Vertical	Vertical	Vertical
Age of Test (Days):	48	48	48
Depth of Penetration (mm):	7	6	4

Comments: Tested outside of the standard at 6 bar of pressure.

Certified that the test was determined in accordance with BSEN 12390-8:2019

Signed:



Gareth Botha - Laboratory Supervisor
for and on behalf of **SOCOTEC UK Limited**